



## ***Fire Prevention Bureau Plan Review***

**Date:** March 29, 2017

**From:** Jeff Werre, Assistant Fire Marshal

**Re:** Permit number: SSDP2016-00415

Project name: King County Trail Phase 2B

Plans dated: 10/21/16

Listed below are comments/conditions regarding our plan review for the permit number which is noted above. If you have any questions regarding these comments please feel free to call (425) 313-3324.

Please submit for re-review when these items below have been addressed.

- Submit all proposed changes to driveways/access points to existing structures to Eastside Fire for review. We will need the existing condition as well as the proposed change for each specific lot. We will address each change individually.
- All bollards installed along the trail shall be removable to allow EF&R access to the trail. Submit design for bollards to EF&R for review.